



Capstone MicroTurbines for CHP

Blue Mountain Ski Resort, Collingwood, Ontario, Canada



James Kennedy, On Power Systems, 905-881-6644, jkennedy@onpower.com.

Blue Mountain Case Study

- Summary
- Design
- Performance
- Economics
- Lessons Learned
- Approvals
- Canadian & Ontario Market





Blue Mountain Summary




- 30kW Capstone Microturbine & Unifin Heat Exchanger (HX), expandable to 120kW.
- Turbine outside, HX and stand alone monitoring system inside
- Phase I: Heat for DHW & Laundry - 30kW.
- Phase II: Pool(s), hot tubs, glycol loop - 60kW
- Phase III: Other DHW

| | | |
|-------------------------------------|------------------|--------------|
| • Project Managers: | On Power Systems | |
| • Project | Plan vs. | Actual Dates |
| – Equipment Delivery | Jan 2003 | Jan 2003 |
| – System Commissioned | Feb 2003 | June 2003 |
| – Re-Commissioned (due to approval) | | October 2003 |
| – Monitoring | Feb 2003 | June 2003 |

Design & installation

Power Control & Interconnection



Performance Monitoring

- Input: Gas consumption,
- Output: Power Output, Flow, Temperature = energy

Mechanical

10'- VENT c/w RAIN CAP
ABOVE TOP OF ROOF


8'- EXHAUST DUCT c/w
2" INSULATION AND
WEATHER PROOFING

5'- CAPPED CONNECTION
FOR FUTURE c/w
2" INSULATION AND
WEATHER PROOFING

5'-

ONT-13
C-30
MICROTURBINE

HEAT
RECOVERY
UNIT





Performance

| | | | |
|----------------------|------|-------|-----------|
| 2003 May 29 22:45:00 | 3490 | 18 | 12628.188 |
| 2003 May 29 23:00:00 | 3491 | 18.01 | 12634.146 |
| 2003 May 29 23:15:00 | 3493 | 18.02 | 12640.14 |
| 2003 May 29 23:30:00 | 3495 | 18.04 | 12646.098 |
| 2003 May 29 23:45:00 | 3496 | 18.05 | 12652.074 |

| Cumulative | (m³) | (MWh) | (kWh) |
|----------------------|---|----------------------------|-------------------------------|
| | Gas Consumption (m ³) | Thermal Energy (MWh) | Electrical Energy (kWh) |
| Hourly input: output | 6 (m ³) | 0.05 (MWh) | 23.886 (kWh) |
| Energy Equivalent | 36145.144 | 18050 | 12652.074 |

Efficiency (Gas energy equivalent/Thermal + electrical energy) 84.94%



Feasibility Stage 2



Cash Flow Analysis for Hot Water CHP Equipment Purchase

| | Blue Mountain | Cdn \$ | U.S. \$ |
|-----------------------------|---------------|-------------------|-------------------|
| M3S-28R-FG4-AUMO | | \$ 60,000 | \$ 37,500 |
| MG4-C2 | | \$ 21,500 | \$ 13,438 |
| engineering | | \$ 5,000 | \$ 3,125 |
| monitoring system | | \$ 3,000 | \$ 1,875 |
| Electrical | | \$ 16,000 | \$ 10,000 |
| Mechanical | | \$ 25,500 | \$ 15,938 |
| M & E upgrades + Misc. | | \$ 14,000 | \$ 8,750 |
| Estimated shipping costs | | \$ 1,500 | \$ 938 |
| Project Management | | \$ 3,500 | \$ 2,188 |
| 60R-HG4-BUMO | | \$ 79,088 | \$ 49,430 |
| Upgrades, i.e., comp., etc. | | \$ 40,000 | \$ 28,571 |
| Total Project Price | | \$ 269,088 | \$ 171,751 |

Inputs

| | | |
|--|------------------|-------------------------------|
| Equipment Installed Cost | \$270,000 | |
| Installed Cost per kWe | \$3,000 | |
| Maintenance Cost | \$0.010 | per kWh |
| Average Electric Utility Energy Rate | \$0.090 | per kWh |
| Average Electric Utility Demand Rate | \$10.49 | per kW per Month |
| Average Gas Rate | \$10.50 | per MM BTU (HHV) |
| Nominal kWe Rating | 90 | kW |
| Average Hot Water Load | 180 | kW thermal = 614,340 BTU / hr |
| Efficiency of Traditional Hot Water Heater | 75% | based on LHV |
| Hours of Operation | 8,760 | hours per year |
| Heat Rate | 12,200 | BTU per kWh (HHV) |

| Year | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|---|-------------|--|-------------|---------------------------|-------------|-------------|-------------|----------------------------|-------------|-------------|-------------|
| Energy Bill Savings | | | | | | | | | | | |
| Avoided Site Electric Energy Costs | | \$70,956 | \$70,956 | \$70,956 | \$70,956 | \$70,956 | \$70,956 | \$70,956 | \$70,956 | \$70,956 | \$70,956 |
| Avoided Site Electric Demand Charge | | \$11,329 | \$11,329 | \$11,329 | \$11,329 | \$11,329 | \$11,329 | \$11,329 | \$11,329 | \$11,329 | \$11,329 |
| Avoided Traditional Water Heater Gas Cost | | \$83,714 | \$83,714 | \$83,714 | \$83,714 | \$83,714 | \$83,714 | \$83,714 | \$83,714 | \$83,714 | \$83,714 |
| | | \$165,999 | \$165,999 | \$165,999 | \$165,999 | \$165,999 | \$165,999 | \$165,999 | \$165,999 | \$165,999 | \$165,999 |
| Fuel for CHP | | (\$100,994) | (\$100,994) | (\$100,994) | (\$100,994) | (\$100,994) | (\$100,994) | (\$100,994) | (\$100,994) | (\$100,994) | (\$100,994) |
| Net Energy Bill Savings | | \$65,005 | \$65,005 | \$65,005 | \$65,005 | \$65,005 | \$65,005 | \$65,005 | \$65,005 | \$65,005 | \$65,005 |
| Expenses | | | | | | | | | | | |
| Maintenance Costs | | (\$5,913) | (\$5,913) | (\$5,913) | (\$5,913) | (\$5,913) | (\$5,913) | (\$5,913) | (\$5,913) | (\$5,913) | (\$5,913) |
| Net Variable Cost Savings | | | | | | | | | | | |
| Savings Before Depreciation & Taxes | | \$59,092 | \$59,092 | \$59,092 | \$59,092 | \$59,092 | \$59,092 | \$59,092 | \$59,092 | \$59,092 | \$59,092 |
| Return on Investment | | | | | | | | | | | |
| Equipment Installed Cost | \$270,000 | assumes straight line, no residual value | | | | | | | | | |
| Depreciation Tax Benefit | 60% | \$32,400 | \$32,400 | \$32,400 | \$32,400 | \$32,400 | | | | | |
| Savings Before Taxes | | \$91,492 | \$91,492 | \$91,492 | \$91,492 | \$91,492 | \$59,092 | \$59,092 | \$59,092 | \$59,092 | \$59,092 |
| Annual Cash Flow | (\$270,000) | \$91,492 | \$91,492 | \$91,492 | \$91,492 | \$91,492 | \$59,092 | \$59,092 | \$59,092 | \$59,092 | \$59,092 |
| | | | | 5 year Cumulative savings | | | \$457,461 | 10 year Cumulative savings | | | \$752,922 |
| Net Present Value at 10% | \$196,289 | | | | | | | | | | |
| Internal Rate of Return | 29% | | | | | | | | | | |
| Payback Period | 3.0 | years | | | | | | | | | |

Lessons Learned



- Stay away from flammable materials (*photo*)
- Buy in from all groups as to scope of project
- Dual Mode vs. Grid-Connect *Re: expectations during blackouts*
- Enclosure forethought *Re: Canadian winters*
- Capstone's iCHP unit over Turbine and separate HX
- Start with a feasibility study, then design the system, then verify with approval agencies, then negotiate price



Approvals

- TSSA (Technical Safety Std Authority) *Regulate boilers, etc,*
- ORD issued April 2003 to classify microturbines for Ontario
- “Hydro One” Re: Interconnection Agreement
- OEB (*Ontario Energy Board*) coming with new interconnection standards - *not a factor on Blue Mountain.*
- ESA - Electrical Safety Authority Re: Electrical inter-connection



Canadian & Ontario Market

- Canada “committed” to Kyoto accord
- Canadian Markets - B.C., QC, & Man. Have Hydro-electricity
- Alberta de-regulated, Ontario’s de-regulation reversed after Ontario Hydro broken into OPG & Hydro One.
- Stranded debt of former Ontario Hydro @ \$ 20.2 Billion & rising
(Province’s population @ 10M)
- Power shortage risks:
 - 1.Nuclear Plants - 3 plants producing 40% of province’s power, one of which is experiencing downtime due to a lengthy, costly refurbishment
(\$1,25B for one of 4 reactors, closed in 1997 to have been re-opened in 2000 @ a total cost of \$780M, is now estimated @ \$4B for all 4 units).
 2. Commitment to de-commissioning Coal plants *(30% of province’s power)*